

# Suite Doors and Doorways

<b>Door Width</b>	<p>Suite entry doors shall provide a clear opening of not less than 850 mm</p> <p>Doorways for common living areas, including a minimum of one accessible bathroom and one accessible bedroom, within suites shall provide a clear opening width of not less than 800 mm</p>
<b>Door Hardware</b>	<p>Doors shall be operable by devices which do not require tight grasping or twisting of the wrist as the only means of operation</p> <p>Doors shall operate when a force of not more than 22 N is applied at the handle, push plate or latch releasing device</p>
<b>Door Thresholds</b>	<p>In doorways, where thresholds are not flush with the floor, the difference in level shall be not more than 13 mm and shall be bevelled</p>

# Suite Doors and Doorways

## Door Clearance

Door assemblies for suite entry and common living areas, including a minimum of one accessible bathroom and one accessible bedroom, shall have a clear and level area:

- when the door swing is away from this area, not less than 1220 mm long by a width equal to the door assembly width plus not less than 300 mm clear space beside the latching jamb of the door
- when the door swing is toward this area, not less than 1500 mm long by a width equal to the door assembly width plus not less than 600 mm clear space beside the latching jamb of the door