

Outlets / Switches / Other Environmental Controls

Controls and Switches	Controls for the operation of building services or safety devices, including electrical switches, thermostats and intercom switches, intended to be operated by the occupant and located in or adjacent to an accessible path of travel as well as within a suite shall be accessible to a person in a wheelchair, operable with one hand, and shall be no higher than 1200 mm above the floor
Outlets	Electrical, cable and phone outlets intended to be used by the occupant and located in or adjacent to an accessible path of travel as well as within a suite shall be no lower than 455 mm above the floor
Telephone Jacks / Outlets	Telephone jacks shall be no farther than 200mm from an electrical outlet in the accessible bedroom
Switch Types	All switch types shall be operable with a closed fist (such as rocker switches)
Visual Alarm	Wiring for a visual alarm shall be tied into the fire alarm system for the future installation of such in the living room and the accessible bedroom

http://www.housing.gov.bc.ca/building/code/access_summary.htm